



**PRE-BID QUERIES RAISED DURING PRE-BID MEETING  
OPEN E-TENDER FOR  
ANNUAL RATE CONTRACT FOR PROCUREMENT OF ODORIZING UNIT**



Tender Doc No. REPL/MNGL/OU/07/21  
Tender Type- Open

Date / Time of Pre- Bid :  
18/10/2021 / 11:00:00

Sr. No.	Section	Tender Clause No. / Annexures	Page No.	Tender Clause	Bidder Query	REPL/MNGL Comments
<b>Technical Queries</b>						
1	Section-V Technical Specification			230 VAC power supply and solar power supply. & Solar power supply.	Kindly confirm if the solar panel is to be considered in scope of supply. Also if the same is in bidder scope of supply , please confirm if the same will be installed in Safe / hazardous area	Solar panel in bidders scope. Hazardous area
2	Section-V Technical Specification	1.0 Scope Of Work	71 of 105	Comprehensive AMC for 0+4 years (1 year warranty period + 4 years)	Kindly provide the Scope of work for comprehensive AMC.	Comprehensive AMC includes but not limited to spares, consumables, scheduled and breakdown maintenance through qualified manpower including travelling, boarding and lodging, special tools required, if any.  Supply of Odorant is excluded from the AMC
3	Section-V Technical Specification	DATA SHEET- ODORIZING UNIT	73 of 105	Primary Power Supply – Solar panel	Kindly provide us in details of Solar panel mounting location i.e. Safe area or hazardous area.	Hazardous Area
4	Section-V Technical Specification	DATA SHEET- ODORIZING UNIT	73 of 105	Primary Power Supply – Solar panel	Kindly provide the battery backup hours required for Solar Power Back up.	72 hrs.
5	Section-V Technical Specification	DATA SHEET- ODORIZING UNIT	73 of 105	Secondary Power Supply Through UPS	Kindly confirm that the UPS for the Secondary power supply will be in M/s. MNGL Scope..	MNGL Scope
6	Section-V Technical Specification	1.2. System Description- Odorizing System	72 of 105	Odorant Injection Panel: - Primary pneumatic driven Pump shall be used for injection of odorant into the pipeline	Kindly confirm both Working and Standby Pump will be pneumatic positive displacement pump.	Bidder's Understanding is correct.
7	Section-V Technical Specification	DATA SHEET- ODORIZING UNIT	73 of 105	Pump: pneumatic positive displacement pump	Kindly confirm both Working and Standby Pump will be pneumatic positive displacement pump.	Bidder's Understanding is correct.
8	Section-V Technical Specification	DATA SHEET- ODORIZING UNIT	73 of 105	SIL 2 Certificate.	Kindly confirm that SIL 2 Certificate will applicable only for Level transmitter. For other components SIL 2 Certificate is not applicable .	Bidder's Understanding is correct.
9	Section-V Technical Specification	DATA SHEET- ODORIZING UNIT	73 of 105	Level Switch	Kindly note that level measurement will done by the Level transmitter itself and provided notification through the Electronic control panel. Since level switch is not required. Hence, we request you to kindly remove the level switch from the Specification	Tender Condition Prevails

**Commercial**



PRE-BID QUERIES RAISED DURING PRE-BID MEETING  
OPEN E-TENDER FOR  
ANNUAL RATE CONTRACT FOR PROCUREMENT OF ODORIZING UNIT



Tender Doc No. REPL/MNGL/OU/07/21  
Tender Type- Open

Date / Time of Pre- Bid :  
18/10/2021 / 11:00:00

Sr. No.	Section	Tender Clause No. / Annexures	Page No.	Tender Clause	Bidder Query	REPL/MNGL Comments
10	Section-III GCC	20. Guarantee	47 of 105	twelve (12) months from the date of the first commercial operation of the Plant for which the materials supplied under the Contract form a part thereof, or twenty-four (24) months from the date of last shipment whichever period shall first expire,	In General, warranty/guarantee period is 12 months from the date of commissioning or 18 months from the date of supply whichever is earlier.  We request you to kindly consider the same for this tender.	Tender Condition Prevails