



**REPLY TO PRE-BID QUERIES RAISED DURING PRE-BID MEETING
OPEN E-TENDER FOR
PROCUREMENT OF CS BALL VALVES (10")**



Tender Doc No. REPL/MNGL/NGV/08/21 Tender Type- Open				Date / Time of Pre- Bid : 25/08/2021 / 11:00:00	
Sr. No.	Section	Page No.	Tender Clause	Bidder Query	REPL/MNGL Comments
Commercial					
1	I	4	4	Delivery Period- Shall be min 20-24 weeks	Delivery period shall be 16 weeks.
2	I	4	6	Being MSME Vendor can we get EMD exemption	Refer Clause 26 of SCC in Tender Document Page No- 65
3	I	4	11	Extention of 14 days from bid due date	Tender Condition Prevails
Technical					
1	Annexure-1	110, 111		As per datasheet valves are required with Gear & Actuator. As per understanding valves are required with actuator + gear. Kindly confirm actuator type – electrical / pneumatic	Manually operated valves with gear is required. Actuator stands deleted.
2	V	-		Valves are required 3.1 or 3.2 Certification	Process inspection shall be as per EN 10204 3.1. However, final inspection of valves shall be as per EN 10204 3.2 by MNGL's TPIA
3	Annexure-1	110, 111		Length of extended stem is not mentioned – can we consider 1200 MM	1200 mm is acceptable however the same will be finalize during detailed engineering.
4	Annexure-1			Valves are metal seated or soft seated – As per temperature requirement can we consider PTFE seat	Seat Material shall be PTFE.
5	V, Annexure-1	77, 110, 111		Painting requirement – painting is as per manufacturer standard / any special painting is required	As per data sheet
6	V	68-77, 110, 111		Please send us technical notes for valves, painting specification, quality assurance plan	Technical notes and painting specifications for Valves in the tender doc. (Section-V) . QAP to be shared saperately.
7	-	-	-	As valve is electrical actuator – send us actuator datasheet along with list of aprved makes	Not Applicable
8	V	77		Please provide painting procedure – i.e. 1st coat & 2nd coat	Please refer Technical Spec. Clause No 7.0 and Data Sheet Clause 15